CERTIFICATE

FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 2041

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

PEKSAN ORMAN ÜRÜNLERİ İMALAT TİC. LTD. ŞTİ.

Sulyman Demirel Indsutrial Zone 113th
Street No.8
Gonen / Isparta
32090
Turkey
Tel: +905346103281

Who fabricate the following timber fire doors and or doorsets:

Halspan EI30, EI60.

have satisfied the requirements of the SDP 01 Timber Fire Door scheme v3.8. This includes the testing of products to **BS EN1634-1:2014+A1:2018**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed on page 2 of this certificate.

Initial Certification: 17 June 2025
Valid to: 10 June 2030
Issue number: 1

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

This certificate consists of 2 pages.
Publication of this certificate is permitted.

IFC Certification Ltd
Ground Floor, Suite A, Building 2
Bear Brook Office Park
Walton Street
Aylesbury
Buckinghamshire
HP21 7GQ
United Kingdom
T +44 (0)1844 276920
www.ifccertification.com

Check the validity of this certificate
by scanning this QR Code or visiting
www.ifccertification.com/search/

IFC Certification

UKAS PRODUCT CERTIFICATION 0175

CERTIFICATE

The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Halspan 30	EI30	BMT/CNA/F13020
Halspan 60	EI60	BMT/FEA/F13021

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

IFC Certification Ltd
Ground Floor, Suite A, Building 2
Bear Brook Office Park
Walton Street
Aylesbury
Buckinghamshire
HP21 7GQ
United Kingdom
T +44 (0)1844 276920
www.ifccertification.com